

Northwest Territories Taltson Outage Data 2003 to 2008

Taltson Outage Data 2003 to 2008

2007/08

Plant	Outage Date	Outage Duration	Outage Cause Code	Percentage of System	Outage Cause Code
		Real Time (Minutes)			
Taltson	18/04/2007	0.33	2	100%	1 Loss of Production
Taltson	03/06/2007	56.00	3	5%	2 Loss of Supply
Taltson	30/06/2007	92.00	5	5%	3 Scheduled
Taltson	01/07/2007	0.03	5	5%	4 Lightning
Taltson	03/07/2007	32.00	7	5%	5 Weather
Taltson	03/07/2007	0.03	5	5%	6 Human
Taltson	04/08/2007	0.03	5	6%	7 External
Taltson	18/08/2007	4.00	3	6%	8 Unknown
Taltson	20/08/2007	15.00	7	6%	
Taltson	09/09/2007	11.00	1	100%	
Taltson	10/09/2007	28.00	1	6%	
Taltson	14/09/2007	23.75	6	100%	
Taltson	27/10/2007	0.33	2	100%	

2006/07

Plant	Outage Date	Outage Duration	Outage Cause Code	Percentage of System
		Real Time (Minutes)		
Taltson	15-Jun-06	15	7	100%
Taltson	14-Jul-06	0	8	4%
Taltson	22-Aug-06	2	4	100%
Taltson	18-Oct-06	0	8	100%
Taltson	12-Jan-07	36	8	8%

2005/06

Plant	Outage Date	Outage Duration	Outage Cause Code	Percentage of System
		Real Time (Minutes)		
Talston	21-Apr-05	0.5	2	100%
Talston	29-Jun-05	0.5	5	100%
Talston	05-Jul-05	0.3	8	100%
Talston	07-Jul-05	0.3	5	100%
Talston	09-Jul-05	0.3	4	100%
Talston	03-Aug-05	6.0	7	100%
Talston	03-Aug-05	27.0	8	9%
Talston	07-Aug-05	0.3	4	100%
Talston	09-Sep-05	76.0	3	100%
Talston	14-Sep-05	108.0	4	100%
Talston	22-Sep-05	109.0	8	7%

2004/05

Plant	Outage Date	Outage Duration	Outage Cause Code	Percentage of System
		Real Time (Minutes)		
Taltson	22-Apr-04	48.0	5	100%
Taltson	16-May-04	0.3	1	100%
Taltson	30-May-04	0.3	8	100%
Taltson	02-Jun-04	19.0	4	86%
Taltson	11-Jun-04	28.0	7	9%
Taltson	20-Jun-04	4.0	7	10%
Taltson	06-Jul-04	21.0	7	7%
Taltson	23-Jul-04	16.0	7	65%
Taltson	30-Jul-04	26.0	4	100%
Taltson	06-Oct-04	31.0	7	100%
Taltson	10-Oct-04	18.0	5	100%
Taltson	24-Dec-04	25.0	8	100%
Taltson	23-Jan-05	27.0	3	11%
Taltson	14-Feb-05	250.0	1	98%
Taltson	22-Mar-05	0.0	8	7%

Northwest Territories Taltson Outage Data 2003 to 2008

2003/04

Plant	Outage Date	Outage Duration	Outage Cause	Percentage of
		Real Time (Minutes)	Code	System
Talston System	21-Apr-03	17.0	2	100%
Talston System	03-Nov-03	91.0	2	100%
Talston System	04-Nov-03	25.0	2	100%
Talston System	23-Nov-03	0.3	2	100%
Talston System	25-Jun-03	0.3	3	100%
Talston System	15-Jun-03	7.0	4	100%
Talston System	02-Jul-03	0.3	4	100%
Talston System	11-Jul-03	0.3	4	100%
Talston System	17-Jul-03	0.3	4	100%
Talston System	22-Jul-03	0.3	4	100%
Talston System	22-Jul-03	0.3	4	100%
Talston System	28-Jul-03	0.3	4	100%
Talston System	01-Aug-03	70.4	4	100%
Talston System	15-May-03	0.3	4	100%
Talston System	05-Aug-03	15.0	6	100%
Talston System	11-Feb-04	0.0	7	13%
Talston System	14-Jul-03	193.0	7	4%
Talston System	18-Apr-03	0.4	8	100%
Talston System	19-Apr-03	0.3	8	100%
Talston System	15-May-03	11.0	8	100%
Talston System	15-May-03	0.0	8	100%
Talston System	01-Jul-03	10.0	8	100%
Talston System	19-Jan-04	59.0	8	8%
Talston System	29-Dec-03	10.0	8	100%

Taltson Outage Data Summary 2003-2008

	Number of O Average Duration (Minutes)	
2007/08	13	20.19
2006/07	5	10.67
2005/06	11	29.84
2004/05	15	34.24
2003/04	24	21.34